

June, 2020

## Fire Compliance Statement:

This compliance statement is relevant for the following products:

**Range:** QuickStyle Panel

**Profiles:** QS6/125/S, QS6/25/D, QS10/25/D, QS10/25/S, QS26/127/50, QS110/100/25

**Substrate:** 12mm MDF Fire Retardant

**Finish:** Inluxe Image

**Acoustic Backing:** Sonus Acoustic Backing 1.0

The above Atkar Group QuickStyle perforated and slotted panels have been tested at Exova Warringtonfire Aust according to AS/NZ 5637.1-2015 and AS/ISO 9705-2003.

**Test Report No.:** SFC 53221400.2 **Issue Date:** 15/03/2018

**Test Specimen Description:** Assessment includes the fire hazard performance of 12mm thickness Atkar MDF-FR panels, with a dry film/foil facing (Inluxe Image) and integral acoustic scrim backing (Sonus Acoustic Backing 1.0) and various concentration and sizes of perforated holes or slots having overall free open area from 4.38% to 32.58%.

**Test Result:** In cooperation with H. Wong & O. Saad from Exova Warringtonfire Aust, the results of the testing were evaluated as **Product Group Number Classification 2**.

Based on the test results it can be concluded that Atkar Group panels with the same panel thickness, film face, acoustic scrim backing area and overall free open area from 4.38% to 32.58% would achieve **Product Group Number Classification 2** as defined in Specification C1.10, (4)(b) of Volume 1 of the Building Code of Australia.

### Product Reference:

QuickStyle Panel Code	Panel Type	Open Area %	Infinity Panel Reference
QS6/125/S	Perforated	17.26%	AP125S/60
QS6/25/D	Perforated	8.62%	AP250D/60
QS10/25/D	Perforated	23.98%	AP250D/100
QS10/25/S	Perforated	12.18%	AP250S/100
QS26/127/50	Slotted	21.78%	AS26-50/127
QS110/100/25	Slotted	28.46%	AS11-25/80

Atkar Group can provide a copy of the above fire certificate on request. If you have any further questions, please contact Atkar Group on [enquires@atkar.com.au](mailto:enquires@atkar.com.au) or on 03 9796 3333.