

June, 2020

Fire Compliance Statement:

This compliance statement is relevant for the following products:

Range: QuickStyle Panel

Profile: QS Solid

Substrate: 12mm MDF - Fire Retardant & 12mm MDF Black - Fire Retardant

Finish: Inlux Image

The substrate for the above QuickStyle solid panels has been tested at AWTA Product Testing according to AS/NZ 5637.1-2015.

Test Report No.: 16-004836 **Issue Date:** 03/10/2016

Test Specimen Description: Fire rated medium density fibre board (MDF - FR) in black or brown with nominal mass per unit area/density of 770kg/m³.

Test Result: In cooperation with Chris Campbell from AWTA Product Testing, the results of the testing were evaluated as **Product Group Number Classification 1.**

Based on the above test results it can be concluded that Atkar Group QuickStyle solid panels which use the same material and density as specimen tested above and is coated with Inlux Image (dry film measuring less than 20 microns or 0.02mm thick), would achieve **Product Group Number Classification 1** as defined in Specification C1.10, 4(b) and Deemed-to Satisfy Provision C1.10 (c)(viii) of Volume 1 of the Building Code of Australia.

Atkar Group can provide a copy of the above fire certificate on request. If you have any further questions, please contact Atkar Group on enquires@atkar.com.au or on 03 9796 3333.